

## **Uttarakhand Livestock Development Board**

Pashudhan Bhawan, Ist Floor, Mothrowala Road, P.O. Mothrowala, Dehradun-248001,

Telefax: 0135-2532619

Email: <a href="mailto:ceo\_uldb@rediffmail.com">ceo\_uldb@rediffmail.com</a> Website: <a href="mailto:www.uldb.org">www.uldb.org</a>

GSTIN: 05AABFU8674M1ZK

Dated: 22 March 2019

Letter No. 5072 / ULDB/PROC./Vol.XV/2018-19

## **Clarification & Amendment**

Bid Ref. No. 4857/ULDB/PROC./Vol.XV/2018-19 Dated: 08<sup>th</sup> March 2019

Kindly look in to the following clarification/ amendment in Bid Reference No.4857/ULDB/PROC./Vol.XV/ 2018-19 Dated: 08<sup>th</sup> March 2019:

S. No.	Reference	Clarification & Amendment
1	Page No. 39: SCHEDULE: TWENTY ONE PART A	Diesel generator 20 KVA Silent, 3 cylinder, water cooling system, Single phase. Auto start system. Suitable Earthing GI type and connection to the panal to be done. Quote for only one model in accordance to the specification desired, technical bid with multiple option shall be summarily rejected. Warranty: 2 years.
	SPECIFICATION OF 20 KVA SILENT GENERATOR:	Should be read as  Diesel generator 20 KVA Silent, 2 to 3 cylinder, water cooling system, Single
		phase. Auto start system. Suitable Earthing GI type and connection to the panel to be done. Quote for only one model in accordance to the specification desired, technical bid with multiple option shall be summarily rejected.
		Installation Material Required:  1. Armoured Cable (25 Sqmm x 4 Core): 140 Meter  2. Control Cable 91.5 mm x 4Core): 140 Meter  3. G.I. Earthing (Chemical): 2 Nos.
		4. Change Over Switch (63 Amp.): 1 No. Foundation of Generator Set is not required. Complete Installation is required. Warranty: 2 years.

Other Terms & conditions will remain same as described in Bid Reference No. 4857/ULDB/PROC./Vol.XV/2018-19 Dated: 08<sup>th</sup> March 2019.

Chief Executive Officer

Uttarakhand Livestock Development Board